

April 2, 2009

California Regional Water Quality Control Board
North Coast Region
5550 Skylane Boulevard, Ste A
Santa Rosa, CA 95403
(707) 576-2220

Notice of Proposed No Further Action

Pelican Bay State Prison
5905 Lake Earl Drive
Crescent City
Case No. 1TDN163

End of Public Comment Period: May 2, 2009

This notice invites the public to review and comment on the pending decision to require no further action regarding petroleum release at 5905 Lake Earl Drive in Crescent City, California (Site).

Problem Description:

Two underground storage tanks (USTs) were removed under the supervision of the Del Norte County Department of Environmental Health from the Site and associated piping was closed in-place. One 4,000-gallon diesel fuel UST and one 6,000-gallon gasoline fuel UST were removed on July 10-11, 2007. Minor soil impact was identified in the subsurface at the former UST locations. The former USTs were located in the southwest part of the Site.

Corrective Action:

The former USTs were disposed of off-site. Associated piping was back-flushed clean and closed in-place.

Status of Contaminants in Groundwater:

Groundwater impacts were not identified through drilling and sample collection.

Regional Water Board staff intends to concur with no further action because no public comments were received during the 30-day public notice unless comments and/or new information is submitted demonstrating that this case does not meet the requirements of no further action. If you would like to review the case file, appointments are recommended and can be scheduled by calling (707) 576-2220. Please contact David W. Parson, PG 6037, CEG 1889 at (707) 576-2556 or e-mail, dparson@waterboards.ca.gov with any questions or comments. Written comments may be sent to the attention of David W. Parson.

(40209_DWP_PelicanBayStatePrison_NFANotice)

California Environmental Protection Agency

Recycled Paper